



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

License No: 40055/RFL/NMSB/2026

Dated: 06/04/2026

District Office,
Fire and Rescue Service,
Vellore District.

RENEWAL OF FIRE LICENSE

Ref: (1) Letter no:380788 from the PREMJI NEURO HOSPITAL, Dated: 20/03/2026

The Fire License is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for In the name of PREMJI NEURO HOSPITAL, S.F.No.457/4, CHITTERI ROAD, THORAPADI, OPP E.B .OFFICE, NEAR LADIES JAIL, VELLORE TALUK, VELLORE DISTRICT -632002. Consisting of Ground floor + first floor with the Height of 6.5 Meters and total built-up area in 1328 Sqm within the jurisdiction of Vellore based on the inspection was done by the StationOfficer Vellore on 04/04/2026. Subject to the condition noted thereon and such other conditions as may be prescribed. This license is valid for **THREE YEAR** from 04/04/2026 to 03/04/2029 and should be renewed on before 03/04/2029.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Dos & Donts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per NBC, 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Station Officer, Vellore, 1997
Northwestern Region - District
Officer,
Home Department

District Office, Vellore
Date: 07-Apr-2026 11:45:24

Fire and Rescue Services

Vellore District



To:

PREMJI NEURO HOSPITAL,
S.F.No.457/4, CHITTERI ROAD,
THORAPADI, OPP E.B .OFFICE,
NEAR LADIES JAIL,
VELLORE TALUK,
VELLORE DISTRICT -632002.

Signature valid

Signed by: District Officer Vellore,
Northwestern Region - District
Officer,
Home Department
Date:07-Apr-2026 11:45:24